

Letter No. 71/SFS/22/09/2023

Date : - 22.09.2023

Fire station Officer, Rajgir

To,

The Principal
Daffodil Convent School
Manpur, Giriyak Block (Nalanda)

Sub : - Inspection Report regarding fire precautionary / measures in your school.

Sir,

In view of your letter dated 11/09/2023, I inspected your school premises, Manpur (Giriyak Block) on dated 15/09/2023. During inspection I found that the school is of 4 hrs fire resistance capacity and following active and passive fire protection arrangements :

1. School has three stair cases.
2. Corridors have enough width.
3. Every floor protected by fire extinguishers.

Suggestion

All firefighting equipment should be maintained every time and a mock drill should also be done once in three months.


Yours sincerely
अग्नि शामाल य पदाधिकारी
Fire Station Officer,
Bihar Sharif


Principal
DAFFODIL CONVENT SCHOOL
Manpur, Giriyak Block
Nalanda - 803109 (Bihar)


Manager
Daffodil Convent School
Manpur, Giriyak Block
Nalanda - 803109

FIRE SAFETY CERTIFICATE

No. 2023-24/FS/71

Date : 22.09.2023

Certified that he **Daffodil Convent School, Manpur (Giriak Block)** (name of the building of premises) at **Manpur (Giriak Block) Nalanda (Bihar)** comprised of **02** basement (s) and **03** (upper floors) owned/occupied by **Daffodil Convent School, Manpur (Giriak Block)** (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of state / UT fire Service Rules, and verified by the officers concerned of fire service on **15/09/2023** (date of inspection) in the presence of **Mr.Sanjeev kumar** and **Mr.Deoniti Prasad** (name and addresses of the Principal / Manager or his representative) and that the building/premises is fit for occupancy class **Group B** with effect from **22/09/2023** for a period of **01** year in accordance with rule and subject to compliance of the conditions.

Issued on 22/09/2023 by

- Strike out whichever is not applicable.

Signature with Seal

Name :

Madan Kumar

Designation :

Fire Station Officer

To

The PrincipalDaffodil Convent SchoolManpur (Giriak Block) Nalanda

(Name and address of the Institution)

ENDORSEMENT

The No Objection Certificate issued Fire Service stand cancelled and annulled due to

(reasons to be recorded).

Principal
DAFFODIL CONVENT SCHOOL
Manpur, Giriak Block
Nalanda - 803109 (Bihar)

Manager
Daffodil Convent School
Manpur, Giriak Block
Nalanda - 803109