

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

F.No. 477-IRDate : 14/04/2026

It is certified that an inspection team headed by Rajesh Kumar, Chemist (Name of officers with designation) from Public Health Division, Biharsharif (Name of Department/Office) inspected the Daffodil Convent School, Manpur, Giriyak Block, Nalanda (Name & Address of the School) on 10/04/2026 and found that the Daffodil Convent School , Manpur, Nalanda (Name of School) has safe drinking water facilities for the students and members of staff of the institution and is maintain the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T.Govt.

The above valid for a period of Six months. .

Signature with Seal :-

Name :- Ramashankar Singh

Designation :- Executive Engineer
Public Health Division, Biharsharif
Executive Engineer
P.H. Division, Biharsharif

To

The Pncipal
Daffodil Convent School,
Manpur, Giriyak Block, Dist.- Nalanda
(Name & Address of the Institution)

Manager
Daffodil Convent School
Ma pur, Giri k Block
Nalanda-803 09

Principal
DAFFODIL CONVENT SCHOOL
Manpur, Giriyak Block
Nalanda - 803109 (Bihar)

**Government of Bihar
Public Health Engineering Department
Water Quality Report**

Format: I


District Name Nalanda

Sample Collected by :- School Staff

Sample Collection date :- 21/04/2026

Sl. No.	Block	Panchayat	Village	Name of Habitation	Ward No.	Location of Source	Test result													Source of water		
							pH	Turbidity	EC	TDS	TH	Ca	Mg	Cl	Alk. a.	Fe	NO ₂	SO ₄	F		T. Coll	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	
1	Giriyak	Puraini	Manpur	Manpur		Daffodil Convent School	8.08	0.4	450	300	200	40	14	40	210	0.06	0.421	6.2	0.91	<1.1	North Side Tube Well	
2	Giriyak	Puraini	Manpur	Manpur		Daffodil Convent School	7.56	0.1	460	310	210	40	14	40	220	0.07	1.31	6.4	1.07	<1.1	South side Tube Well	
							6.5-8.5	1.0	-	500	200	75	30	250	200	0.3	45	200	1.0	-		
							Permissible Limit * in absence of alternate source	5.0	-	2000	600	200	100	1000	600	NR	NR	400	1.5	**	-	

Remarks :- Analyzed sample water are satisfactory for drinking & domestic purpose



[Signature]
Principal
DAFFODIL CONVENT SCHOOL
Manpur, Giriyak Block
Nalanda - 805109

[Signature]
Manager School
Daffodil Convent School
Manpur, Giriyak Block
Nalanda-805109

[Signature]
Chemist
Public Health Division, Bihar Sharif
Nalanda
Public Health Division
Bihar Sharif (Nalanda)